

## ENCLOSURE

to the certificate for qualification for test activities No 274/2021 dated May 30, 2021

### Specification of activities of TEST LABORATORY E 28 PRO 8 s.r.o. Pardubice

Number	Title and Subject of test	Method Identification
<b>1</b>	<b>Tests of protective and working tools</b>	
1.1	Voltage testers	ZM-01 / PNE 35 9700, ZM-09, ČSN EN 61243-1, -2
1.2	Phasing sets	ZM-01 / PNE 35 9700 ČSN EN 61481
1.3	Handling bars, life hook, shorting set bars	ZM-01 / PNE 35 9700, ZM-08, ČSN 35 9701, ČSN 35 9703, ČSN EN 61219
1.4	Equipment for earthing and short-circuiting	ZM-01 / PNE 35 9700, ZM-08 ZM 20, MP 06, ČSN 35 9705, ČSN EN 61219, ČSN EN 61230
<b>10</b>	<b>Tests of HV metal-enclosed switchgears</b>	ČSN EN 60060-1,
10.1	Measurement of insulation resistance	ČSN EN 61439-1,
10.2	AC voltage test	ČSN EN 61439-2,
10.4	Measurement of transient resistance	ČSN EN 61439-5

#### CONDITIONS:

- All activities must be performed in compliance with actual text in force of mentioned standards and regulations. During the use of appropriate standard it is necessary always to arise from such edition of the Czech standard which assumes the latest edition of undated CENELEC or IEC standards. The same is valid for AHVL test methodologies and for internal regulations.
- Operation scope is limited by the performance and voltage of the testing sources. All the testing circuits, testing and measuring methods must comply with ČSN EN 60060-1, ČSN EN 60060-2 and ČSN EN 60060-3.
- The validity of the certificate is conditioned by the Head of the Test Laboratory

**Ing. Miroslav Líbal**

the employee with the qualification in accordance with §6, §8 of Decree No. 50/78.

- The right of signature of the test protocols is also provided by the deputy head of test laboratory

**Mr. Jakub Řáda**

- A change of the head of Test Laboratory must be reported to the board of AZVN, who will prolong the certificate validity after checking the qualification of the new laboratory head.
- Extension of the Test Laboratory activity is possible on the base of notifying the board of AZVN and their subsequent inspection of the Test Laboratory. They will issue amendment to this appendix.



  
 Ing. Václav Aschenbrenner  
 Chairman